## **SIEMENS**

## Data sheet

6ES7317-2FK14-0AB0

SIMATIC S7-300 CPU317F-2 PN/DP, CENTRAL PROCESSING UNIT WITH 1.5 MBYTE WORKING MEMORY, 1. INTERFACE MPI/DP 12MBIT/S, 2. INTERFACE ETHERNET PROFINET, WITH 2 PORT SWITCH, MICRO MEMORY CARD NECESSARY

	TOTAL OTHERS, MICHO MEMORY OF ALB NEGLEGO ACT		
General information			
Hardware product version	01		
Firmware version	V3.2		
Engineering with			
Programming package	STEP 7 V5.5 or higher, Distributed Safety V5.4 SP4		
Supply voltage			
Rated value (DC)			
● 24 V DC	Yes		
permissible range, lower limit (DC)	20.4 V		
permissible range, upper limit (DC)	28.8 V		
external protection for power supply lines (recommendation)	2 A min.		
Mains buffering			
Mains/voltage failure stored energy time	5 ms		
• Repeat rate, min.	1 s		
Input current			
Current consumption (rated value)	750 mA		
Current consumption (in no-load operation), typ.	150 mA		
Inrush current, typ.	4 A		
I²t	1 A <sup>2</sup> ·s		
Power loss			
Power loss, typ.	4.65 W		
Memory			
Work memory			
• integrated	1 536 kbyte		
• expandable	No		
<ul> <li>Size of retentive memory for retentive data</li> </ul>	256 kbyte		
blocks			
Load memory			
<ul><li>Plug-in (MMC)</li></ul>	Yes		
<ul><li>Plug-in (MMC), max.</li></ul>	8 Mbyte		
<ul> <li>Data management on MMC (after last programming), min.</li> </ul>	10 y		

Backup	
• present	Yes; Guaranteed by MMC (maintenance-free)
• without battery	Yes; Program and data
CPU processing times	
for bit operations, typ.	0.025 μs
for word operations, typ.	0.03 µs
for fixed point arithmetic, typ.	0.04 μs
for floating point arithmetic, typ.	0.16 μs
CPU-blocks	
Number of blocks (total)	2 048; (DBs, FCs, FBs); the maximum number of loadable blocks can be reduced by the MMC used.
DB	
• Number, max.	2 048; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
<ul><li>Number, max.</li></ul>	2 048; Number range: 0 to 7999
● Size, max.	64 kbyte
FC	
Number, max.	2 048; Number range: 0 to 7999
● Size, max.	64 kbyte
ОВ	
● Size, max.	64 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	1; OB 1
<ul><li>Number of free cycle OBs</li><li>Number of time alarm OBs</li></ul>	1; OB 1 1; OB 10
·	
Number of time alarm OBs	1; OB 10
<ul><li>Number of time alarm OBs</li><li>Number of delay alarm OBs</li></ul>	1; OB 10 2; OB 20, 21
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 - isochronous mode is possible either on DP or
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> <li>Number of isochronous mode OBs</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously)
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> <li>Number of isochronous mode OBs</li> <li>Number of startup OBs</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously) 1; OB 100
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> <li>Number of isochronous mode OBs</li> <li>Number of startup OBs</li> <li>Number of asynchronous error OBs</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously) 1; OB 100 6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO)
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> <li>Number of isochronous mode OBs</li> <li>Number of startup OBs</li> <li>Number of asynchronous error OBs</li> <li>Number of synchronous error OBs</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously) 1; OB 100 6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO)
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> <li>Number of isochronous mode OBs</li> <li>Number of startup OBs</li> <li>Number of asynchronous error OBs</li> <li>Number of synchronous error OBs</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously) 1; OB 100 6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO) 2; OB 121, 122
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> <li>Number of isochronous mode OBs</li> <li>Number of startup OBs</li> <li>Number of asynchronous error OBs</li> <li>Number of synchronous error OBs</li> <li>Nesting depth</li> <li>per priority class</li> <li>additional within an error OB</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously) 1; OB 100 6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO) 2; OB 121, 122
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> <li>Number of isochronous mode OBs</li> <li>Number of startup OBs</li> <li>Number of asynchronous error OBs</li> <li>Number of synchronous error OBs</li> <li>Number of synchronous error OBs</li> </ul> Nesting depth <ul> <li>per priority class</li> <li>additional within an error OB</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously) 1; OB 100 6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO) 2; OB 121, 122
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> <li>Number of isochronous mode OBs</li> <li>Number of startup OBs</li> <li>Number of asynchronous error OBs</li> <li>Number of synchronous error OBs</li> <li>Nesting depth</li> <li>per priority class</li> <li>additional within an error OB</li> </ul>	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously) 1; OB 100 6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO) 2; OB 121, 122
<ul> <li>Number of time alarm OBs</li> <li>Number of delay alarm OBs</li> <li>Number of cyclic interrupt OBs</li> <li>Number of process alarm OBs</li> <li>Number of DPV1 alarm OBs</li> <li>Number of isochronous mode OBs</li> <li>Number of startup OBs</li> <li>Number of asynchronous error OBs</li> <li>Number of synchronous error OBs</li> <li>Number of synchronous error OBs</li> </ul> Nesting depth <ul> <li>per priority class</li> <li>additional within an error OB</li> </ul> Counters, timers and their retentivity S7 counter	1; OB 10 2; OB 20, 21 4; OB 32, 33, 34, 35 1; OB 40 3; OB 55, 56, 57 1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not simultaneously) 1; OB 100 6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO) 2; OB 121, 122

— lower limit	0		
	511		
— upper limit			
— preset	Z 0 to Z 7		
Counting range	V		
— can be set	Yes		
— lower limit	0		
— upper limit	999		
IEC counter			
Number	Unlimited (limited only by RAM capacity)		
S7 times			
• Number	512		
Retentivity			
— adjustable	Yes		
— lower limit	0		
— upper limit	511		
— preset	No retentivity		
Time range			
— lower limit	10 ms		
— upper limit	9 990 s		
IEC timer			
• present	Yes		
• Type	SFB		
. , , , ,			
• Number	Unlimited (limited only by RAM capacity)		
Number	Unlimited (limited only by RAM capacity)		
	Unlimited (limited only by RAM capacity)  All, max. 256 KB		
Number  Data areas and their retentivity			
Number  Data areas and their retentivity retentive data area in total			
Number  Data areas and their retentivity retentive data area in total Flag	All, max. 256 KB		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> </ul>	All, max. 256 KB 4 096 byte		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> </ul>	All, max. 256 KB 4 096 byte Yes; From MB 0 to MB 4095		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> </ul>	All, max. 256 KB  4 096 byte  Yes; From MB 0 to MB 4095  MB 0 to MB 15		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> <li>Number of clock memories</li> </ul>	All, max. 256 KB  4 096 byte  Yes; From MB 0 to MB 4095  MB 0 to MB 15		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> <li>Number of clock memories</li> <li>Data blocks</li> </ul>	All, max. 256 KB  4 096 byte  Yes; From MB 0 to MB 4095  MB 0 to MB 15  8; 1 memory byte		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Number, max.</li> </ul>	All, max. 256 KB  4 096 byte Yes; From MB 0 to MB 4095 MB 0 to MB 15 8; 1 memory byte  2 048; Number range: 1 to 16000		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Number, max.</li> <li>Size, max.</li> </ul>	All, max. 256 KB  4 096 byte Yes; From MB 0 to MB 4095 MB 0 to MB 15 8; 1 memory byte  2 048; Number range: 1 to 16000 64 kbyte		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Number, max.</li> <li>Size, max.</li> <li>Retentivity adjustable</li> </ul>	All, max. 256 KB  4 096 byte Yes; From MB 0 to MB 4095 MB 0 to MB 15 8; 1 memory byte  2 048; Number range: 1 to 16000 64 kbyte Yes; via non-retain property on DB		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Number, max.</li> <li>Size, max.</li> <li>Retentivity adjustable</li> <li>Retentivity preset</li> </ul>	All, max. 256 KB  4 096 byte Yes; From MB 0 to MB 4095 MB 0 to MB 15 8; 1 memory byte  2 048; Number range: 1 to 16000 64 kbyte Yes; via non-retain property on DB		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Number, max.</li> <li>Size, max.</li> <li>Retentivity adjustable</li> <li>Retentivity preset</li> <li>Local data</li> </ul>	All, max. 256 KB  4 096 byte Yes; From MB 0 to MB 4095 MB 0 to MB 15 8; 1 memory byte  2 048; Number range: 1 to 16000 64 kbyte Yes; via non-retain property on DB Yes		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Number, max.</li> <li>Size, max.</li> <li>Retentivity adjustable</li> <li>Retentivity preset</li> <li>Local data</li> <li>per priority class, max.</li> </ul>	All, max. 256 KB  4 096 byte Yes; From MB 0 to MB 4095 MB 0 to MB 15 8; 1 memory byte  2 048; Number range: 1 to 16000 64 kbyte Yes; via non-retain property on DB Yes		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Number, max.</li> <li>Size, max.</li> <li>Retentivity adjustable</li> <li>Retentivity preset</li> <li>Local data</li> <li>per priority class, max.</li> </ul> Address area	All, max. 256 KB  4 096 byte Yes; From MB 0 to MB 4095 MB 0 to MB 15 8; 1 memory byte  2 048; Number range: 1 to 16000 64 kbyte Yes; via non-retain property on DB Yes		
<ul> <li>Number</li> <li>Data areas and their retentivity</li> <li>retentive data area in total</li> <li>Flag</li> <li>Number, max.</li> <li>Retentivity available</li> <li>Retentivity preset</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Number, max.</li> <li>Size, max.</li> <li>Retentivity adjustable</li> <li>Retentivity preset</li> <li>Local data</li> <li>per priority class, max.</li> </ul> Address area <ul> <li>I/O address area</li> </ul> I/O address area	All, max. 256 KB  4 096 byte Yes; From MB 0 to MB 4095 MB 0 to MB 15 8; 1 memory byte  2 048; Number range: 1 to 16000 64 kbyte Yes; via non-retain property on DB Yes  32 768 byte; Max. 2048 bytes per block		

Imputs				
Process image  Inputs Outputs Outputs Outputs Outputs Outputs, adjustable Outputs, adjustable Outputs, adjustable Outputs, adjustable Outputs, adjustable Outputs, default Outputs Outputs Outputs Of subprocess images, max.  I; With PROFINET IO, the length of the user data is limited to 1600 bytes  Digital channels  Inputs Outputs Of which central Outputs	of which distributed			
Process image	— Inputs	8 192 byte		
Inputs	— Outputs	8 192 byte		
Outputs	Process image			
In liquits, adjustable Outputs, adjustable Inputs, default Outputs, default Outputs Inputs Official channels Inputs Outputs Ou	• Inputs	8 192 byte		
Outputs, adjustable     Inputs, default     Outputs, default     Outputs, default     Outputs, default     Outputs, default     Outputs, default     Subprocess images     Number of subprocess images, max.	Outputs	8 192 byte		
Injusts, default 256 byte     Outputs, default 256 byte  Subprocess images     Number of subprocess images, max. 1; With PROFINET IO, the length of the user data is limited to 1600 bytes  Digital channels  Injusts 65 536     — of which central 1024  Outputs 65 536     — of which central 1024  Analog channels  Injusts 4 096     — of which central 256  Outputs 4 096     — of which central 256  Outputs 4 096     — of which central 256  Outputs 3 096     — of which central 256  Plandware configuration  Number of expansion units, max. 3  Number of DP masters  Integrated 1  Via CP  Number of operable FMs and CPs (recommended)  FM 8  CP, PIP 8  CP, LAN 10  Rack  Racks, max. 4  Modules per rack, max. 8  Time of day  Clock  Hardware clock (real-time) Yes  Freentive and synchronizable Yes	<ul> <li>Inputs, adjustable</li> </ul>	8 192 byte		
Outputs, default	<ul> <li>Outputs, adjustable</li> </ul>	8 192 byte		
Subprocess images  Number of subprocess images, max.  1; With PROFINET IO, the length of the user data is limited to 1600 bytes  Digital channels  Inputs  of 5536  of which central  1024  Analog channels  Inputs  of which central  1024  Analog channels  Inputs  of which central  4096  of which central  256  Outputs  of which central  256  Augusta of Which central  Washer of which central  Brandware configuration  Number of expansion units, max.  Number of DP masters  integrated  via CP  Number of operable FMs and CPs (recommended)  FM  CP, PtP  CP, LAN  10  Rack  Racks, max.  Modules per rack, max.  Modules per rack, max.  Modules per rack, max.  Imme of day  Clock  Hardware clock (real-time)  retentive and synchronizable  Free flaves  Swi; At 40 °C ambient temperature	<ul> <li>Inputs, default</li> </ul>	256 byte		
Number of subprocess images, max.   1; With PROFINET IO, the length of the user data is limited to 1600 bytes	Outputs, default	256 byte		
Digital channels	Subprocess images			
	Number of subprocess images, max.			
- of which central   1 024    • Outputs   65 536	Digital channels			
Outputs     — of which central     — of which central     1 024  Analog channels      Inputs     — of which central     — of which central     Outputs     — of which central     256      Outputs     — of which central     256  Hardware configuration  Number of expansion units, max.  Number of DP masters      integrated     integrated     ivia CP  Number of operable FMs and CPs (recommended)      FM     CP, PtP     8     CP, PtP     8     CP, LAN     10  Rack      Racks, max.     Modules per rack, max.      Modules per rack, max.  Time of day  Clock      Hardware clock (real-time)     retentive and synchronizable     Rackup time     6 wk; At 40 °C ambient temperature	• Inputs	65 536		
— of which central 1 024  Analog channels  Inputs 4 096 — of which central 256  Outputs 4 096 — of which central 256  Hardware configuration  Number of expansion units, max. 3  Number of DP masters  Integrated 1 Via CP 4  Number of operable FMs and CPs (recommended)  FM 8 CP, PtP 8 CP, LAN 10  Rack  Racks, max. 4 Modules per rack, max. 8  Time of day  Clock  Hardware clock (real-time) Yes Fretentive and synchronizable FMs and synchronizable Fretentive and synchronizable Yes Sacky At 40 °C ambient temperature	— of which central	1 024		
Analog channels	Outputs	65 536		
	— of which central	1 024		
of which central 256  Outputs	Analog channels			
Outputs Of which central  Hardware configuration  Number of expansion units, max.  Number of DP masters  integrated via CP  Number of operable FMs and CPs (recommended)  FM CP, PtP CP, LAN  Rack Racks, max. Modules per rack, max. Modules per rack, max. Hardware clock (real-time) retentive and synchronizable Backup time  A 4096  256  Hardware configuration  A 4096  A 509  A 509  A 509  A 609  A 709	• Inputs	4 096		
of which central 256  Hardware configuration  Number of expansion units, max. 3  Number of DP masters  • integrated 1 • via CP 4  Number of operable FMs and CPs (recommended)  • FM 8 • CP, PtP 8 • CP, LAN 10  Rack  • Racks, max. 4 • Modules per rack, max. 4 • Modules per rack, max. 8  Time of day  Clock  • Hardware clock (real-time) Yes • retentive and synchronizable Yes • Backup time 6 wk; At 40 °C ambient temperature	— of which central	256		
Hardware configuration  Number of expansion units, max.  Number of DP masters  integrated via CP  Number of operable FMs and CPs (recommended)  FM CP, PtP 8 CP, LAN 10  Rack Rack Racks, max. Modules per rack, max.  Modules per rack, max.  Hardware clock (real-time) retentive and synchronizable Backup time  6 wk; At 40 °C ambient temperature	Outputs	4 096		
Number of expansion units, max.  Number of DP masters  integrated  via CP  Number of operable FMs and CPs (recommended)  FM  CP, PtP  CP, LAN  Rack  Racks, max.  Modules per rack, max.  Modules per rack, max.  Hardware clock (real-time)  retentive and synchronizable  Backup time  6 wk; At 40 °C ambient temperature	— of which central	256		
Number of DP masters  • integrated • via CP  Number of operable FMs and CPs (recommended)  • FM • CP, PtP  • CP, LAN  Rack  • Racks, max. • Modules per rack, max.  • Modules per rack, max.  • Hardware clock (real-time) • retentive and synchronizable • Backup time  • Winter the synchronizable of the synchron	Hardware configuration			
integrated via CP  A  Number of operable FMs and CPs (recommended)  FM CP, PtP 8 CP, LAN 10  Rack  Rack  Racks, max. Modules per rack, max.  Modules per rack, max.  Firme of day  Clock  Hardware clock (real-time) retentive and synchronizable Backup time  6 wk; At 40 °C ambient temperature	•	3		
via CP  Number of operable FMs and CPs (recommended)      FM	Number of DP masters			
Number of operable FMs and CPs (recommended)  • FM  • CP, PtP  • CP, LAN  10  Rack  • Racks, max.  • Modules per rack, max.  • Modules per rack, max.  Time of day  Clock  • Hardware clock (real-time)  • retentive and synchronizable  • Backup time  • Wes  • Wes  • Wes  • Wes  • Racks, max.  • Modules per rack, max.  • Modules per rack, max.   **Time of day  **Clock  • Hardware clock (real-time)  • Racks, max.  • Wes  • Racks, max.  • Modules per rack, max.  **Time of day  **Clock  • Hardware clock (real-time)  • Racks, max.  • Wes  • Racks, max.  • Modules per rack, max.  **Time of day  **Clock  • Hardware clock (real-time)  • Racks, max.  • Wes  • Racks, max.  • Modules per rack, max.  **Time of day  **Clock  • Hardware clock (real-time)  • Racks, max.  • Authorized the maximum of the maxim	• integrated	1		
FM CP, PtP 8 CP, LAN 10  Rack  Racks, max. Modules per rack, max.  Modules per rack, max.  Hardware clock (real-time) retentive and synchronizable Backup time  8  Kack  Yes 6 wk; At 40 °C ambient temperature		4		
<ul> <li>CP, PtP</li> <li>CP, LAN</li> <li>Rack</li> <li>Racks, max.</li> <li>Modules per rack, max.</li> <li>Modules per rack, max.</li> <li>Elacks</li> <li>Wes</li> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Wes</li> <li>6 wk; At 40 °C ambient temperature</li> </ul>	Number of operable FMs and CPs (recommended)			
CP, LAN  Rack  Racks, max.  Modules per rack, max.  Modules per rack, max.  Immediately the control of the con	● FM			
Rack  Racks, max.  Modules per rack, max.  Imme of day  Clock  Hardware clock (real-time)  retentive and synchronizable  Backup time  Yes  6 wk; At 40 °C ambient temperature	• CP, PtP	8		
<ul> <li>Racks, max.</li> <li>Modules per rack, max.</li> </ul> Time of day Clock <ul> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>4</li> <li>8</li> </ul> Yes <ul> <li>6 wk; At 40 °C ambient temperature</li> </ul>	● CP, LAN	10		
Modules per rack, max.  Time of day  Clock  Hardware clock (real-time) retentive and synchronizable Backup time  8  Ves  6 wk; At 40 °C ambient temperature	Rack			
Time of day  Clock  • Hardware clock (real-time)  • retentive and synchronizable  • Backup time  Yes  • wk; At 40 °C ambient temperature	● Racks, max.			
Clock  • Hardware clock (real-time)  • retentive and synchronizable  • Backup time  Yes  • Wk; At 40 °C ambient temperature	Modules per rack, max.	8		
<ul> <li>Hardware clock (real-time)</li> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Yes</li> <li>6 wk; At 40 °C ambient temperature</li> </ul>	•			
<ul> <li>retentive and synchronizable</li> <li>Backup time</li> <li>Yes</li> <li>6 wk; At 40 °C ambient temperature</li> </ul>		V		
Backup time  6 wk; At 40 °C ambient temperature				
·				
Deviation per day, may     10 s: Typ: 2 s				
Deviation per day, max.	Deviation per day, max.	10 s; Typ.: 2 s		

Behavior of the clock following POWER-ON	Clock continues running after POWER OFF		
Behavior of the clock following expiry of backup	Clock continues to run with the time at which the power failure		
period	occurred		
Operating hours counter			
• Number	4		
Number/Number range	0 to 3		
Range of values	0 to 2^31 hours (when using SFC 101)		
Granularity	1 hour		
• retentive	Yes; Must be restarted at each restart		
Clock synchronization			
• supported	Yes		
• to MPI, master	Yes		
• to MPI, slave	Yes		
• to DP, master	Yes; With DP slave only slave clock		
● to DP, slave	Yes		
● in AS, master	Yes		
• in AS, slave	Yes		
• on Ethernet via NTP	Yes; As client		
Digital inputs			
Digital inputs  Number of digital inputs	0		
realiser of digital inputs			
Digital outputs			
Number of digital outputs	0		
Analog inputs			
Number of analog inputs	0		
Analog outputs			
Number of analog outputs	0		
Interfaces  Number of industrial Ethernet interfaces	1		
Number of Industrial Ethernet Interfaces  Number of RS 485 interfaces	1		
Number of RS 422 interfaces	0		
Number of No 422 interfaces	O .		
1. Interface			
Interface type	Integrated RS 485 interface		
Physics	RS 485		
Isolated	Yes		
Power supply to interface (15 to 30 V DC), max.	200 mA		
Functionality	V		
• MPI	Yes		
PROFIBUS DP master	Yes		
PROFIBUS DP slave	Yes		
<ul> <li>Point-to-point connection</li> </ul>	No		

PI					
• Transmission rate, max.	12 Mbit/s				
Services					
<ul><li>— PG/OP communication</li></ul>	Yes				
— Routing	Yes				
<ul> <li>Global data communication</li> </ul>	Yes				
<ul> <li>S7 basic communication</li> </ul>	Yes				
— S7 communication	Yes				
<ul> <li>S7 communication, as client</li> </ul>	No; but via CP and loadable FB				
<ul> <li>S7 communication, as server</li> </ul>	Yes				
P master					
• Transmission rate, max.	12 Mbit/s				
<ul> <li>Number of DP slaves, max.</li> </ul>	124				
Services					
— PG/OP communication	Yes				
— Routing	Yes				
— Global data communication	No				
— S7 basic communication	Yes; I blocks only				
— S7 communication	Yes				
<ul> <li>S7 communication, as client</li> </ul>	No				
— S7 communication, as server	Yes				
— Equidistance	Yes				
— Isochronous mode	Yes; OB 61; isochronous mode can only be used alternatively or PROFIBUS DP or PROFINET IO				
— SYNC/FREEZE	Yes				
<ul> <li>Activation/deactivation of DP slaves</li> </ul>	Yes				
<ul> <li>Number of DP slaves that can be simultaneously activated/deactivated, max.</li> </ul>	8				
<ul> <li>— Direct data exchange (slave-to-slave communication)</li> </ul>	Yes; As subscriber				
— DPV1	Yes				
Address area					
— Inputs, max.	8 kbyte				
— Outputs, max.	8 kbyte				
User data per DP slave					
— Inputs, max.	244 byte				
— Outputs, max.	244 byte				
P slave					
Transmission rate, max.	12 Mbit/s				
automatic baud rate search	Yes; only with passive interface				
• Address area, max.	32				
User data per address area, max.	32 byte				

Services	
— PG/OP communication	Yes
— Routing	Yes; Only with active interface
<ul> <li>Global data communication</li> </ul>	No
<ul> <li>S7 basic communication</li> </ul>	No
— S7 communication	Yes
<ul> <li>S7 communication, as client</li> </ul>	No
<ul> <li>S7 communication, as server</li> </ul>	Yes; Connection configured on one side only
<ul> <li>— Direct data exchange (slave-to-slave communication)</li> </ul>	Yes
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte

2. Interface	
Interface type	PROFINET
Physics	Ethernet RJ45
Isolated	Yes
automatic detection of transmission rate	Yes; 10/100 Mbit/s
Autonegotiation	Yes
Autocrossing	Yes
Change of IP address at runtime, supported	Yes
Interface types	
<ul> <li>Number of ports</li> </ul>	2
• integrated switch	Yes
Media redundancy	
• supported	Yes
<ul> <li>Switchover time on line break, typ.</li> </ul>	200 ms; PROFINET MRP
<ul> <li>Number of stations in the ring, max.</li> </ul>	50
Functionality	
• MPI	No
<ul> <li>PROFINET IO Controller</li> </ul>	Yes; Also simultaneously with IO-Device functionality
PROFINET IO Device	Yes; Also simultaneously with IO Controller functionality
PROFINET CBA	Yes
PROFIBUS DP master	No
PROFIBUS DP slave	No
Open IE communication	Yes; Via TCP/IP, ISO on TCP, and UDP
Web server	Yes
<ul> <li>Number of HTTP clients</li> </ul>	5
PROFINET IO Controller	
Transmission rate, max.	100 Mbit/s

Services	
— PG/OP communication	Yes
— Routing	Yes
— S7 communication	Yes; with loadable FBs, max. configurable connections: 16, max. number of instances: 32
— Isochronous mode	Yes; OB 61; isochronous mode can only be used alternatively on PROFIBUS DP or PROFINET IO
— Open IE communication	Yes; Via TCP/IP, ISO on TCP, and UDP
— IRT	Yes
— Shared device	Yes
— Prioritized startup	Yes
<ul> <li>Number of IO devices with prioritized startup, max.</li> </ul>	32
— Number of connectable IO Devices, max.	128
— Of which IO devices with IRT, max.	64
— of which in line, max.	64
<ul> <li>Number of IO Devices with IRT and the option "high flexibility"</li> </ul>	128
— of which in line, max.	61
<ul> <li>Number of connectable IO Devices for RT, max.</li> </ul>	128
— of which in line, max.	128
<ul> <li>Activation/deactivation of IO Devices</li> </ul>	Yes
<ul> <li>Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8
<ul> <li>IO Devices changing during operation (partner ports), supported</li> </ul>	Yes
— Number of IO Devices per tool, max.	8
— Device replacement without swap medium	Yes
— Send cycles	$250~\mu s,500~\mu s,1~ms;2~ms,4~ms$ (not in the case of IRT with "high flexibility" option)
— Updating time	250 μs to 512 ms (depending on the operating mode, see Manual "S7-300 CPU 31xC and CPU 31x, Technical Data" for more details)
Address area	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte
— User data consistency, max.	1 024 byte
OFINET IO Device	
Services	
— PG/OP communication	Yes
— Routing	Yes

- S7 communication Yes; with loadable FBs, max. configurable connections: 16, max. number of instances: 32 - Isochronous mode Yes; Via TCP/IP, ISO on TCP, and UDP — Open IE communication - IRT Yes; With SFB 73 / 74 prepared for loadable PROFlenergy - PROFlenergy standard FB for I-Device Yes - Shared device 2 - Number of IO Controllers with shared device, max. Transfer memory 1 440 byte; Per IO Controller with shared device - Inputs, max. 1 440 byte; Per IO Controller with shared device - Outputs, max. Submodules 64 - Number, max. 1 024 byte - User data per submodule, max. PROFINET CBA Yes acyclic transmission Yes • cyclic transmission Open IE communication 16 • Number of connections, max. • Local port numbers used at the system end 0, 20, 21, 23, 25, 80, 102, 135, 161, 443, 8080, 34962, 34963, 34964, 65532, 65533, 65534, 65535 • Keep-alive function, supported Yes

=							
=	m	$\mathbf{a}$	r	$\cap$	$\sim$	$\cap$	Is
	un	~	8	_	v	_	10

## Open IE communication

• TCP/IP

- Number of connections, max. 16

— Data length for connection type 01H, max.

32 768 byte — Data length for connection type 11H, max.

- several passive connections per port,

supported

1 460 byte

Yes

16

• ISO-on-TCP (RFC1006)

Yes; via integrated PROFINET interface and loadable FBs

- Number of connections, max.

32 768 byte - Data length, max.

• UDP

- Number of connections, max.

16

- Data length, max.

1 472 byte

Isochronous operation (application synchronized up to terminal)

Yes; Via PROFIBUS DP or PROFINET interface

Communication functions				
PG/OP communication	Yes			
Data record routing	Yes			
Global data communication				
• supported	Yes			
<ul> <li>Number of GD loops, max.</li> </ul>	8			
<ul> <li>Number of GD packets, max.</li> </ul>	8			
<ul> <li>Number of GD packets, transmitter, max.</li> </ul>	8			
<ul> <li>Number of GD packets, receiver, max.</li> </ul>	8			
<ul> <li>Size of GD packets, max.</li> </ul>	22 byte			
<ul> <li>Size of GD packet (of which consistent), max.</li> </ul>	22 byte			
S7 basic communication				
• supported	Yes			
<ul> <li>User data per job, max.</li> </ul>	76 byte			
<ul> <li>User data per job (of which consistent), max.</li> </ul>	76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or X_GET as server)			
S7 communication				
• supported	Yes			
• as server	Yes			
• as client	Yes; via integrated PROFINET interface and loadable FB or via CP and loadable FB			
User data per job, max.	See online help of STEP 7 (shared parameters of the SFBs/FBs and of the SFCs/FCs of S7 Communication)			
S5 compatible communication				
• supported	Yes; via CP and loadable FC			
Open IE communication				
• TCP/IP	Yes; via integrated PROFINET interface and loadable FBs			
• UDP	Yes; via integrated PROFINET interface and loadable FBs			
Web server				
• supported	Yes			
<ul> <li>Number of HTTP clients</li> </ul>	5			
<ul> <li>User-defined websites</li> </ul>	Yes			
PROFINET CBA (at set setpoint communication load)				
<ul> <li>Setpoint for the CPU communication load</li> </ul>	50 %			
<ul> <li>Number of remote interconnection partners</li> </ul>	32			
<ul> <li>Number of functions, master/slave</li> </ul>	30			
<ul> <li>Total of all master/slave connections</li> </ul>	1 000			
<ul> <li>Data length of all incoming connections master/slave, max.</li> </ul>	4 000 byte			
<ul> <li>Data length of all outgoing connections master/slave, max.</li> </ul>	4 000 byte			
<ul> <li>Number of device-internal and PROFIBUS interconnections</li> </ul>	500			

<ul> <li>Data length of device-internal und PROFIBUS interconnections, max.</li> </ul>	4 000 byte
Data length per connection, max.	1 400 byte
Remote interconnections with acyclic transmission	
— Sampling frequency: Sampling time, min.	500 ms
<ul> <li>Number of incoming interconnections</li> </ul>	100
<ul> <li>Number of outgoing interconnections</li> </ul>	100
<ul> <li>Data length of all incoming interconnections, max.</li> </ul>	2 000 byte
<ul> <li>Data length of all outgoing interconnections, max.</li> </ul>	2 000 byte
<ul> <li>Data length per connection, max.</li> </ul>	1 400 byte
Remote interconnections with cyclic transmission	
<ul> <li>Transmission frequency: Transmission interval, min.</li> </ul>	10 ms
<ul> <li>Number of incoming interconnections</li> </ul>	200
<ul> <li>Number of outgoing interconnections</li> </ul>	200
<ul> <li>Data length of all incoming interconnections, max.</li> </ul>	2 000 byte
<ul> <li>Data length of all outgoing interconnections, max.</li> </ul>	2 000 byte
Data length per connection, max.	450 byte
HMI variables via PROFINET (acyclic)	
<ul> <li>Number of stations that can log on for HMI variables (PN OPC/iMap)</li> </ul>	3; 2x PN OPC/1x iMap
<ul> <li>HMI variable updating</li> </ul>	500 ms
<ul> <li>Number of HMI variables</li> </ul>	200
<ul> <li>Data length of all HMI variables, max.</li> </ul>	2 000 byte
PROFIBUS proxy functionality	
— supported	Yes
<ul> <li>Number of linked PROFIBUS devices</li> </ul>	16
<ul> <li>Data length per connection, max.</li> </ul>	240 byte; Slave-dependent
Number of connections	
• overall	32
<ul> <li>usable for PG communication</li> </ul>	31
<ul> <li>reserved for PG communication</li> </ul>	1
<ul> <li>adjustable for PG communication, min.</li> </ul>	1
<ul> <li>adjustable for PG communication, max.</li> </ul>	31
<ul> <li>usable for OP communication</li> </ul>	31
— reserved for OP communication	1
— adjustable for OP communication, min.	1
<ul> <li>adjustable for OP communication, max.</li> </ul>	31

<ul> <li>usable for S7 basic communication</li> </ul>	30
— reserved for S7 basic communication	0
<ul> <li>adjustable for S7 basic communication, min.</li> </ul>	0
<ul> <li>adjustable for S7 basic communication, max.</li> </ul>	30
• usable for S7 communication	16
<ul> <li>reserved for S7 communication</li> </ul>	0
<ul> <li>adjustable for S7 communication, min.</li> </ul>	0
— adjustable for S7 communication, max.	16
• total number of instances, max.	32
usable for routing	X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max. 14; X2 as PROFINET: 24 max.

S7 message functions	
Number of login stations for message functions, max.	32; Depending on the configured connections for PG/OP and S7
	basic communication
Process diagnostic messages	Yes
simultaneously active Alarm-S blocks, max.	300

Test commissioning functions		
Status block	Yes; Up to 2 simultaneously	
Single step	Yes	
Number of breakpoints	4	
Status/control		
<ul> <li>Status/control variable</li> </ul>	Yes	
Variables	Inputs, outputs, memory bits, DB, times, counters	
<ul> <li>Number of variables, max.</li> </ul>	30	
— of which status variables, max.	30	
— of which control variables, max.	14	
Forcing		
• Forcing	Yes	
<ul><li>Forcing, variables</li></ul>	Inputs, outputs	
<ul> <li>Number of variables, max.</li> </ul>	10	
Diagnostic buffer		
• present	Yes	
<ul> <li>Number of entries, max.</li> </ul>	500	
— adjustable	No	
<ul><li>of which powerfail-proof</li></ul>	100; Only the last 100 entries are retained	
<ul> <li>Number of entries readable in RUN, max.</li> </ul>	499	
— can be set	Yes; From 10 to 499	
— preset	10	
Service data		
• can be read out	Yes	

Ambient conditions	
Ambient temperature during operation	
● min.	0 °C
• max.	60 °C
Configuration	
Configuration software	
• STEP 7	Yes; V5.5 or higher
Programming	
Command set	see instruction list
<ul> <li>Nesting levels</li> </ul>	8
<ul><li>System functions (SFC)</li></ul>	see instruction list
<ul> <li>System function blocks (SFB)</li> </ul>	see instruction list
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	Yes
— GRAPH	Yes
— HiGraph®	Yes
Know-how protection	
<ul> <li>User program protection/password protection</li> </ul>	Yes
<ul> <li>Block encryption</li> </ul>	Yes; With S7 block Privacy
Dimensions	
Width	40 mm
Height	125 mm
Depth	130 mm
Weights	
Weight, approx.	340 g
last modified:	08/12/2017