## **SIEMENS**

## Data sheet

## 6ES7315-2AG10-0AB0

\*\*\* SPARE PART\*\*\* SIMATIC S7-300, CPU 315-2DP CPU WITH MPI INTERFACE INTEGRATED 24 V DC POWER SUPPLY 128 KBYTE WORKING MEMORY 2. INTERFACE DP-MASTER/SLAVE MICRO MEMORY CARD NECESSARY



General information	
Hardware product version	01
Firmware version	V2.6
Engineering with	
<ul> <li>Programming package</li> </ul>	STEP 7 V5.2 + SP1 or higher with HW update
Supply voltage	
Rated value (DC)	
• 24 V DC	Yes
permissible range, lower limit (DC)	20.4 V
permissible range, upper limit (DC)	28.8 V
external protection for power supply lines	2 A min.
(recommendation)	
Input current	
Current consumption (rated value)	0.8 A
Current consumption (in no-load operation), typ.	60 mA
Inrush current, typ.	2.5 A
l²t	0.5 A <sup>2</sup> ·s
Power loss	

Power loss, typ.	2.5 W
Memory	
Work memory	
• integrated	128 kbyte; For program and data
• expandable	No
Load memory	
• Plug-in (MMC)	Yes
<ul> <li>Plug-in (MMC), max.</li> </ul>	8 Mbyte
<ul> <li>Data management on MMC (after last programming), min.</li> </ul>	10 y
Backup	
• present	Yes; Guaranteed by MMC (maintenance-free)
• without battery	Yes; Program and data
CPU processing times	
for bit operations, typ.	0.1 µs
for word operations, typ.	0.2 µs
for fixed point arithmetic, typ.	2 µs
for floating point arithmetic, typ.	3 µs
CPU-blocks	
Number of blocks (total)	1 024; (DBs, FCs, FBs OBs, SDBs); the maximum number of loadable blocks can be reduced by the MMC being used.
DB	
• Number, max.	1 023; Number band: 1 to 1023
• Size, max.	16 kbyte
FB	
• Number, max.	1 024; Number range: 0 to 2047
• Size, max.	16 kbyte
FC	
• Number, max.	1 024; Number range: 0 to 2047
• Size, max.	16 kbyte
OB	
• Size, max.	16 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	1; OB 1
<ul> <li>Number of time alarm OBs</li> </ul>	1; OB 10
<ul> <li>Number of delay alarm OBs</li> </ul>	1; OB 20
<ul> <li>Number of cyclic interrupt OBs</li> </ul>	1; OB 35
<ul> <li>Number of process alarm OBs</li> </ul>	1; OB 40
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3; OB 55, 56, 57
Number of startup OBs	1; OB 100
<ul> <li>Number of asynchronous error OBs</li> </ul>	1; OB 80
<ul> <li>Number of synchronous error OBs</li> </ul>	2; OB 121, 122

Nesting depth	
• per priority class	8
<ul> <li>additional within an error OB</li> </ul>	4
Counters, timers and their retentivity	
S7 counter	
• Number	256
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	255
— preset	8
Counting range	
— can be set	Yes
— lower limit	0
— upper limit	999
IEC counter	
• Number	Unlimited (limited only by RAM capacity)
S7 times	
Number	256
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	255
— preset	No retentivity
Time range	
— lower limit	10 ms
— upper limit	9 990 s
IEC timer	
• present	Yes
• Туре	SFB
Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	
retentive data area in total	all
Flag	
• Number, max.	2 048 byte
Retentivity available	Yes; MB 0 to MB 2047
Retentivity preset	MB 0 to MB 15
Number of clock memories	8; 1 memory byte
Data blocks	4.000 Number bends 4 to 4000
• Number, max.	1 023; Number band: 1 to 1023
• Size, max.	16 kbyte

<ul> <li>Retentivity adjustable</li> </ul>	Yes; via non-retain property on DB
Retentivity preset	Yes
Local data	
per priority class, max.	1 024 byte; per block max. 510
Address area	
I/O address area	
Inputs	2 kbyte
Outputs	2 kbyte
of which distributed	
— Inputs	2 kbyte
— Outputs	2 kbyte
Process image	
Inputs	128 byte
Outputs	128 byte
Digital channels	
Inputs	16 384
— of which central	1 024
Outputs	16 384
— of which central	1 024
Analog channels	
• Inputs	1 024
— of which central	256
Outputs	1 024
— of which central	256
Hardware configuration	
Number of expansion units, max.	3
Number of DP masters	
• integrated	1
● via CP	4
Number of operable FMs and CPs (recommended)	
• FM	8
• CP, PtP	8
• CP, LAN	10
Rack	
• Racks, max.	4
<ul> <li>Modules per rack, max.</li> </ul>	8
Time of day	
Clock	
<ul> <li>Hardware clock (real-time)</li> </ul>	Yes
<ul> <li>retentive and synchronizable</li> </ul>	Yes

Backup time	6 wk; At 40 °C ambient temperature
Deviation per day, max.	10 s
Operating hours counter	
Number	1
Number/Number range	0
Range of values	0 to 2^31 hours (when using SFC 101)
Granularity	1 hour
retentive	Yes; Must be restarted at each restart
Clock synchronization	
supported	Yes
• to MPI, master	Yes
• to MPI, slave	Yes
• to DP, master	Yes; With DP slave only slave clock
• to DP, slave	Yes
• in AS, master	Yes
• in AS, slave	No
<ul> <li>on Ethernet via NTP</li> </ul>	No
	NU
Digital inputs	
integrated channels (DI)	0
Digital outputs	
integrated channels (DO)	0
Analog inputs	
integrated channels (AI)	0
Analog outputs	
integrated channels (AO)	0
Interfaces	
Number of industrial Ethernet interfaces	0
Number of RS 485 interfaces	1
Number of RS 422 interfaces	0
1. Interface	
Interface type	Integrated RS 485 interface
Physics	RS 485
Isolated	No
Power supply to interface (15 to 30 V DC), max.	200 mA
Functionality	
• MPI	Yes
<ul> <li>PROFIBUS DP master</li> </ul>	No
PROFIBUS DP slave	No
<ul> <li>Point-to-point connection</li> </ul>	No
MPI	

Number of connections	16
<ul> <li>Transmission rate, max.</li> </ul>	187.5 kbit/s
Services	
— PG/OP communication	Yes
— Routing	Yes
— Global data communication	Yes
— S7 basic communication	Yes
— S7 communication	Yes
— S7 communication, as client	No
- S7 communication, as server	Yes

2. Interface	
Interface type	Integrated RS 485 interface
Physics	RS 485
Isolated	Yes
Power supply to interface (15 to 30 V DC), max.	200 mA
Functionality	
• MPI	No
<ul> <li>PROFIBUS DP master</li> </ul>	Yes
PROFIBUS DP slave	Yes
<ul> <li>Point-to-point connection</li> </ul>	No
DP master	
<ul> <li>Number of connections, max.</li> </ul>	16
<ul> <li>Transmission rate, max.</li> </ul>	12 Mbit/s
<ul> <li>Number of DP slaves, max.</li> </ul>	124; Per station
Services	
— PG/OP communication	Yes
— Routing	Yes
— Global data communication	No
— S7 basic communication	Yes; I blocks only
— S7 communication	Yes
— S7 communication, as client	No
— S7 communication, as server	Yes
— Equidistance	Yes
— Isochronous mode	No
- SYNC/FREEZE	Yes
— DPV1	Yes
Address area	
— Inputs, max.	2 048 byte
— Outputs, max.	2 048 byte
User data per DP slave	
— Inputs, max.	244 byte

— Outputs, max.	244 byte
DP slave	
Number of connections	16
• GSD file	The latest GSD file is available at: http://www.siemens.com/profibus-gsd
• Transmission rate, max.	12 Mbit/s
<ul> <li>automatic baud rate search</li> </ul>	Yes; only with passive interface
<ul> <li>Address area, max.</li> </ul>	32
<ul> <li>User data per address area, max.</li> </ul>	32 byte
Services	
— PG/OP communication	Yes
— Routing	Yes; with interface active
<ul> <li>Global data communication</li> </ul>	No
— S7 basic communication	No
— S7 communication	Yes
— S7 communication, as client	No
— S7 communication, as server	Yes
<ul> <li>Direct data exchange (slave-to-slave communication)</li> </ul>	Yes
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte
Communication functions	
PG/OP communication	Yes
Global data communication	
<ul> <li>supported</li> </ul>	Yes
<ul> <li>Number of GD loops, max.</li> </ul>	8
<ul> <li>Number of GD packets, max.</li> </ul>	8
<ul> <li>Number of GD packets, transmitter, max.</li> </ul>	8
<ul> <li>Number of GD packets, receiver, max.</li> </ul>	8
<ul> <li>Size of GD packets, max.</li> </ul>	22 byte
• Size of GD packet (of which consistent), max.	22 byte
S7 basic communication	
• supported	Yes
• User data per job, max.	76 byte
<ul> <li>User data per job (of which consistent), max.</li> </ul>	76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or X_GET as server)
S7 communication	
• supported	Yes
• as server	Yes
• as client	Yes; Via CP and loadable FB

<ul> <li>User data per job, max.</li> </ul>	180 byte; With PUT/GET
• User data per job (of which consistent), max.	64 byte; as server
S5 compatible communication	
• supported	Yes; via CP and loadable FC
Number of connections	
• overall	16
<ul> <li>usable for PG communication</li> </ul>	15
<ul> <li>reserved for PG communication</li> </ul>	1
<ul> <li>— adjustable for PG communication, min.</li> </ul>	1
<ul> <li>adjustable for PG communication, max.</li> </ul>	15
<ul> <li>usable for OP communication</li> </ul>	15
<ul> <li>reserved for OP communication</li> </ul>	1
— adjustable for OP communication, min.	1
— adjustable for OP communication, max.	15
<ul> <li>usable for S7 basic communication</li> </ul>	12
- reserved for S7 basic communication	0
— adjustable for S7 basic communication,	0
min.	
<ul> <li>— adjustable for S7 basic communication, max.</li> </ul>	12
<ul> <li>usable for routing</li> </ul>	4
-	4
usable for routing     S7 message functions     Number of login stations for message functions, max.	4 16; Depending on the configured connections for PG/OP and S7
S7 message functions	
S7 message functions	16; Depending on the configured connections for PG/OP and S7
S7 message functions Number of login stations for message functions, max.	16; Depending on the configured connections for PG/OP and S7 basic communication
S7 message functions Number of login stations for message functions, max. Process diagnostic messages simultaneously active Alarm-S blocks, max.	16; Depending on the configured connections for PG/OP and S7 basic communication Yes
S7 message functions Number of login stations for message functions, max. Process diagnostic messages	16; Depending on the configured connections for PG/OP and S7 basic communication Yes
S7 message functions Number of login stations for message functions, max. Process diagnostic messages simultaneously active Alarm-S blocks, max. Test commissioning functions	<ul> <li>16; Depending on the configured connections for PG/OP and S7 basic communication</li> <li>Yes</li> <li>40</li> </ul>
S7 message functions Number of login stations for message functions, max. Process diagnostic messages simultaneously active Alarm-S blocks, max. Test commissioning functions Status block	16; Depending on the configured connections for PG/OP and S7 basic communication Yes 40 Yes
S7 message functions         Number of login stations for message functions, max.         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Test commissioning functions         Status block         Single step	16; Depending on the configured connections for PG/OP and S7 basic communication Yes 40 Yes Yes
S7 message functions         Number of login stations for message functions, max.         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Test commissioning functions         Status block         Single step         Number of breakpoints	16; Depending on the configured connections for PG/OP and S7 basic communication Yes 40 Yes Yes
S7 message functions         Number of login stations for message functions, max.         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Test commissioning functions         Status block         Single step         Number of breakpoints         Status/control	16; Depending on the configured connections for PG/OP and S7 basic communication Yes 40 Yes Yes 2
S7 message functions         Number of login stations for message functions, max.         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Test commissioning functions         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable	16; Depending on the configured connections for PG/OP and S7 basic communication         Yes         40         Yes         2         Yes         2         Yes         Yes         2
S7 message functions         Number of login stations for message functions, max.         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Test commissioning functions         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables	16; Depending on the configured connections for PG/OP and S7 basic communication         Yes         40         Yes         2         Yes         Inputs, outputs, memory bits, DB, times, counters
S7 message functions         Number of login stations for message functions, max.         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Test commissioning functions         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.	16; Depending on the configured connections for PG/OP and S7 basic communication         Yes         40         Yes         2         Yes         Inputs, outputs, memory bits, DB, times, counters         30
S7 message functions         Number of login stations for message functions, max.         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Test commissioning functions         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.	16; Depending on the configured connections for PG/OP and S7 basic communication         Yes         40         Yes         2         Yes         10         Yes         2         Yes         30         30
S7 message functions         Number of login stations for message functions, max.         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Test commissioning functions         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.	16; Depending on the configured connections for PG/OP and S7 basic communication         Yes         40         Yes         2         Yes         10         Yes         2         Yes         30         30
S7 message functions         Number of login stations for message functions, max.         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Test commissioning functions         Status block         Single step         Number of breakpoints         Status/control         • Status/control variable         • Variables         • Number of variables, max.         — of which status variables, max.         — of which control variables, max.         — of which control variables, max.         — of which control variables, max.	16; Depending on the configured connections for PG/OP and S7 basic communication         Yes         40         Yes         Yes         2         Yes         Inputs, outputs, memory bits, DB, times, counters         30         30         14

Diagnostic buffer

• present	Yes
<ul> <li>Number of entries, max.</li> </ul>	100
— adjustable	No
Configuration	
Configuration Software	
• STEP 7	Yes; V5.2 SP1 or higher with HW update
Programming	
Command set	see instruction list
Nesting levels	8
<ul> <li>System functions (SFC)</li> </ul>	see instruction list
System function blocks (SFB)	see instruction list
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	Yes
— GRAPH	Yes
— HiGraph®	Yes
Know-how protection	
<ul> <li>User program protection/password protection</li> </ul>	Yes
Dimensions	
Width	40 mm
Height	125 mm
Depth	130 mm
Weights	
Weights Weight, approx.	290 g
	-
last modified:	08/12/2017